



University of Colorado

Denver | Anschutz Medical Campus

FIRE & LIFE SAFETY

Campus Box F-410
1945 N. Wheeling St.
Aurora, Colorado 80045

(303) 724-0293
Pager 266-0053
Fax (303) 724-0969

Fire Alarm Reports October 2011

Anschutz Medical Campus

Day / Date / Time	Location	Disposition
Fri 10/7 12:44 p	Building 406	Smoke detector, listed as unknown cause
Fri 10/21 11:11 a	Pharmacy, 3 rd floor	Smoke detector, due to boil-over on lab hot plate
Mon 10/24 7:59 a	Building 500, ground	Smoke detector, due to steam leak (NO FD)

Denver Campus (LS Center—LS Court—CU Building & Annex)

Day / Date / Time	Location	Disposition
-------------------	----------	-------------

None reported

TOTAL ALARMS FOR MONTH 3

An alarm followed by “**NO FD**” signifies no fire department response. Not initiating a response or cancellation of fire responders (after they have been called to respond) has been accepted, in writing, by the Aurora Fire Department. Our approved policy has specific guidelines that are to be followed prior to cancellation, and it is put into effect only when Facilities Management staff or University Police personnel arrive quickly and determine that the alarm is not an actual fire and that no hazard exists.

Year-to-date

Anschutz Medical Campus:	33
Denver Campus:	3
ALARMS TOTAL:	36
FIRES WITH PROPERTY LOSS: (University loss above \$100.00)	0
FIRE-RELATED INJURIES:	0

This document only applies to buildings owned and operated by the University of Colorado Denver. Please note that University of Colorado Hospital is a separately governed, non-profit entity, and the entire Auraria campus is managed and maintained by the Auraria Higher Education Center (AHEC). In addition, the University of Colorado Denver does not own, nor operate, any student housing. We have no information regarding fire alarms or fire-related incidents in the aforementioned locations or for any leased property.