



University of Colorado

Denver | Anschutz Medical Campus

FIRE & LIFE SAFETY

1945 N. Wheeling St. (Campus Box F-410)
Aurora, Colorado 80045
303 724-0293

Fire Alarm Reports February 2016

Anschutz Medical Campus

Day / Date / Time	Location	Disposition
None		

Denver Campus (LS Center, School of Business Building, and CU Building /Annex)

Day / Date / Time	Location	Disposition
Mon. 2/29 @ 1:07 pm	1250 14 th St 3 rd floor	Smoke discovered: burnt out relay @ water fountain

TOTAL ALARMS FOR MONTH

An alarm followed by “**NO FD**” signifies no fire department response. Not initiating a response or cancellation of fire responders (after they have been called to respond) has been accepted, in writing, by the Aurora Fire Department. Our approved policy has specific guidelines that are to be followed prior to cancellation, and it is put into effect only when Facilities Management staff or University Police personnel arrive quickly and determine that the alarm is not an actual fire and that no hazard exists.

Year-to-date

Anschutz Medical Campus:	3
Denver Campus:	1

ALARMS TOTAL: 4

FIRES WITH PROPERTY LOSS: 0
(University loss above \$100.00)

FIRE-RELATED INJURIES: 0

This document only applies to buildings owned and operated by the University of Colorado Denver. Please note that University of Colorado Hospital is a separately governed, non-profit entity, and the Auraria campus is managed and maintained by the Auraria Higher Education Center (AHEC). In addition, the University of Colorado Denver does not own, nor operate, any student housing. We have no information regarding fire alarms or fire-related incidents in the aforementioned locations or for any leased property.