

FIRE ALARM STATISTICS FOR CU ANSCHUTZ MEDICAL CAMPUS 2018

Facility	Street Address	Total Alarms/ Building	Fire Number	Cause of Alarm	Number of Injuries Requiring Medical Treatment	Number of Deaths Related to Fire	Value of Property Damage Caused by Fire/Smoke
AOI/L15	12631 E. 17th Ave.	1	0	flow	0	0	0
BDC/M20	1775 Aurora Ct.	0	0				
Bldg. 400/Q09	2469 E. 17th Pl.	1	0	1st floor Smoke-False Vacuum dust	0	0	0
Bldg. 401/R09	1784 Racine St.	0	0				
Bldg. 402/S09	12474 E. 19th Ave.	0	0				
Bldg. 406/T09	12477 E. 19th Ave.	0	0				
Bldg. 407/U09	12454 E. 19th Pl.	0	0				
Bldg. 500/Q20	13001 E. 17th Pl.	1	0	2nd Floor-Accidental Pull	0	0	0
Bldg. 532/S21	12856 E. 19th Ave.	0	0				
Bldg. 533/R24	13001 E. 17th Pl.	0	0				
Bldg. 534/S25	13001 E. 17th Pl.	0	0				
Bldg. 610/Q34	13309 E. 17th Pl.	0	0				
Campus Services/T36	1945 N. Wheeling St.	0	0				
Central Utilities Plant/S34	13350 E. 19th Ave.	0	0				
Education One/P26	13070 E. 19th Ave.	0	0				
Education Two-North/P28	13120 E. 19th Ave.	2	0	1). 3rd Floor Smoke-Burnt popcorn. 2). 4th Floor Smoke-Burnt food	0	0	0
Education Two-South/L28	13121 E. 19th Ave.	0	0				
EH&S/R30-R31	13178 E. 19th Ave.	0	0				
Fire Station/X28	1997 Uvalda Ct.	0	0				
Fulginiti Center/R27	13080 E. 9th Ave.	0	0				
Health and Wellness Center/V08	12348 E. Montview Blvd.	0	0				

Health Sciences Library/V23	2950 E. Montview Blvd.	0	0				
Henderson Parking Structure/VI7	12706 E. Montview Blvd.	0	0				
Nighthorse Campbell/M24	13055 E. 17th Ave.	0	0				
PASCAL/P30	13188 E. 19th Ave.	0	0				
Perinatal Research Facility/AK32	13243 E. 23rd Ave.	0	0				
School of Pharmacy/V20	12850 E. Montview Blvd.	1	0	3rd Floor Smoke-Burned out bulb			
Research One-North/P18	12800 E. 19th Ave.	4	0	1). 9th Floor Smoke-Smoking reffridgerator. 2) Smoke-Steam Leak (Vivarium). 3). 8th Floor Smoke-Smoking compressor. 4). Vivarium Smoke-Steam	0	0	0
Research One-South/L18	12801 E. 17th Ave.	5	0	1). 7th Floor Smoke-Burned pan on hot plate. 2). 9th Floor Smoke- Burned food in microwave. 3). 1st Floor Storage- Cut sensor wire, drywall workers. 4). 2nd Floor pull station False. 5). 9th Floor Smoke-Hot plate boiled over.	0	0	0
Research Two/P15	12700 E. 19th Ave.	6	0	1). 3rd Floor Smoke-Food in microwave. 2). 3rd Floor Smoke-Steam. 3). Vivarium Smoke-Steam. 4). 4th Floor Smoke-Hot plate. 5). 6th Floor Smoke-False. 6). Vivarium Smoke-False.	0	0	0
School of Dental Med./L26	13065 E. 17th Ave.	2	0	1). 1st Floor Smoke-Burnt popcorn. 2). Stair Smoke-False, facilities work.	0	0	0
Total CU Anschutz 2018		23	0		0	0	0

FIRE ALARM STATISTICS FOR CU DENVER CAMPUS 2018

Facility	Street Address	Total Alarms/ Building	Fire Number	Cause of Alarm	Number of Injuries Requiring Medical Treatment	Number of Deaths Related to Fire	Value of Property Damage Caused by Fire/Smoke
Academic Building One/ABI	1201 Larimer St.	0	0				
CU Denver Bldg./CU	1250 14th St.	1	0	3rd Floor Conf Rm Smoke-Dust from renovation	0	0	0
CU Denver Business School	1475 Lawrence St.	0	0				
Lawrence Street Center/LW	1380 Lawrence St.	0	0				
Lola & Rob Salazar Student Wellness	1355 12th St.	0	0				
Total CU Denver 2018		1	0		0	0	0